



HARYANA PWD (B&R)
EXECUTIVE ENGINEER,
Provincial Division No.1,
PWD B&R, Kurukshetra-136118.
Ph. No. (01744-239442)
Email ID- pwd-ecpd1-kurukshetra@hry.nic.in

To

✓ The Principal
Shri Ram International Gurukul
Village & PO- Thol
Ismilabad District Kurukshetra

No. 1250

Dated: 13.5.2024

Subject: Regarding issuance of Building Safety Certificate

Reference: Your office letter dated 9.5.2024

In this connection, it is submitted that the building of Shri Ram Interantional Gurukul, Ismilabad District Kurukshetra has been inspected by the Sub Division No.1, PWD B&R, Pehowa along with concerned Junior Engineer and building found to be safe as per visual inspection of the structure of the building. The school Building Safety Certificate is hereby given upto the period 2024-25 with the following conditions:-

1. Building of this school should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the Building.
3. If Building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. School will be responsible for safety of building from every angle and Fire-Fighting equipment should be in functional condition.
5. If the building of the school is to be extended, the same should be first approved from Structural Engineer.
6. Adequate Fire safety may be adopted in the school campus.
7. School authority shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
8. NOC may be considered as cancelled by this office if the college violates any of the above points.

Executive Engineer,
Provincial Division No.1,
PWD B&R, Kurukshetra

DA/ Nil
Endst No.

Dated

Copy forwarded to the SDE, PSD-1, PWD B&R, Pehowa w.r.t his letter No. 351 dated 13.5.2024.

DA/ Nil

Executive Engineer,
Provincial Division No.1,
PWD B&R, Kurukshetra